

The maintenance call provides for the following:

### Service Technician's Checklist

OK Faulty N/A

#### Indoor Unit

- |  |                          |                          |                          |
|--|--------------------------|--------------------------|--------------------------|
| 1. Check air filters . . . . .                                       | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Check blower & air handler operation and lubricate bearings . .   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Check blower belt and tension . . . . .                           | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Check amp draw on blower motor with fan door closed . . . .       | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. Check operation of condensate drain . . . . .                     | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6. Check operational controls and thermostat . . . . .               | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. Visually inspect refrigerant lines for signs of leakage . . . . . | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8. Check temperature difference across evaporator* . . . . .         | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 9. Label a/c breaker or fuse . . . . .                               | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 10. Other _____ . . . . .  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 11. Other _____ . . . . .  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

#### Outdoor Unit

- |  |                          |                          |                          |
|--|--------------------------|--------------------------|--------------------------|
| 1. Visually inspect refrigerant lines for signs of leakage . . . . . | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Inspect condenser coil and clean if necessary . . . . .           | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. Check condenser fan and lubricate bearings . . . . .              | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Check amp draw on condenser fan* . . . . .                        | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. Check condition of the compressor contactor . . . . .             | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6. Check amp draw on compressor* . . . . .                           | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. Check system supply voltage with 24V disconnected . . . . .       | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8. Check voltage across contactor* . . . . .                         | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 9. Check operating temperature* . . . . .                            | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 10. Furnace left operating following check . . . . .                 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 11. Other _____ . . . . .  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 12. Affix service decal to disconnect box or unit . . . . .          | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 13. Leave completed checklist with customer . . . . .                | <input type="checkbox"/> | <input type="checkbox"/> |                          |

\*to be completed if outside ambient temperature is over 55°F

This maintenance does not cover the replacement of parts or additional cleaning materials